



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 24, 2012

Re: Athens County
Village of Chauncey
Notice of Violation
NPDES Permit 0PB00006*HD
Correspondence (PWW)

Mayor and Council
Village of Chauncey
42 Converse Street
Chauncey, Ohio 45719

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of January through November 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
May 2011	001	Total Suspended Solids	7D Conc	45	60.	5/1/2011
May 2011	001	E. coli	7D Conc	284	320	5/1/2011
July 2011	001	E. coli	7D Conc	284	293	7/8/2011
Sept. 2011	001	Chlorine	1D Conc	0.038	0.9	9/12/2011
Sept. 2011	001	Chlorine	1D Conc	0.038	0.7	9/13/2011
Sept. 2011	001	Chlorine	1D Conc	0.038	1.0	9/22/2011
October 2011	001	E. coli	7D Conc	284	1151	10/1/2011
October 2011	001	Chlorine	1D Conc	0.038	0.5	10/17/2011
October 2011	001	Chlorine	1D Conc	0.038	0.5	10/18/2011
October 2011	001	Chlorine	1D Conc	0.038	0.3	10/19/2011
October 2011	001	Chlorine	1D Conc	0.038	0.7	10/20/2011
October 2011	001	Chlorine	1D Conc	0.038	0.6	10/21/2011
October 2011	001	Chlorine	1D Conc	0.038	1.7	10/24/2011
October 2011	001	Chlorine	1D Conc	0.038	0.4	10/25/2011
October 2011	001	Chlorine	1D Conc	0.038	0.5	10/26/2011
October 2011	001	Chlorine	1D Conc	0.038	0.2	10/28/2011
October 2011	001	Chlorine	1D Conc	0.038	0.7	10/31/2011

Notes: 1D Conc = Daily Average Concentration Value
1D Qty = Daily Average Loading Value
7D Conc = Weekly Average Concentration Value
30D Conc = Monthly Average Concentration Value
7D Qty = Weekly Average Loading Value
30D Qty = Monthly Average Loading Value

Southeast District Office
2195 Front Street
Logan, OH 43138-8637

740 | 385 8501
740 | 385 6490 (fax)
www.epa.ohio.gov

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

If you have any questions, please contact me at your convenience.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Abbot Stevenson', with a long horizontal flourish extending to the right.

Ms. Abbot Stevenson
Environmental Engineer
Permits and Compliance Section
Division of Surface Water

AS/dh

c: Joe Riley, Operator of Record