



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 24, 2012

**Re:** Belmont County  
Flushing WWTP  
Self-monitoring Report Violations  
NPDES Permit 0PB00013\*ED  
Correspondence (PWW)

Mayor Barbara Bashline and Village Council  
Village of Flushing  
P.O. Box 66  
Flushing, Ohio 43977

Dear Mayor Bashline and Council Members:

We have received your self-monitoring reports covering the months of January through November 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2011	001	Total Suspended Solids	7D Qty	20.4	28.9931	3/8/2011
October 2011	001	Fecal Coliform	7D Conc	2000	2833	10/22/2011


**NOTES:** 1D Conc = Daily Average Concentration Value  
1D Qty = Daily Average Loading Value  
7D Conc = Weekly Average Concentration Value  
30D Conc = Monthly Average Concentration Value  
7D Qty = Weekly Average Loading Value  
30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed Jeff Vaughn's reports addressing the reasons for the above violations. Flushing must work on reducing inflow and infiltration in the collection system to minimize future effluent violations due to high flows. No additional information is requested at this time.

If you have any questions, please contact me at (740) 380-5284 at your convenience.

Sincerely,



Ms. Abbot Stevenson  
Environmental Engineer  
Permits and Enforcement Section

Division of Surface Water

AS/dh

c: Jeff Vaughn, Vaughn, Coast and Vaughn