



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 23, 2012

**Re:** Athens County  
Village of Albany  
Notice of Violation  
NPDES Permit 0PB00087\*BD  
Correspondence (PWW)

Mayor and Council  
Village of Albany  
5153 Alton Street  
Albany, Ohio 45710

Dear Mayor and Council Members:

We have received your self-monitoring reports covering the months of October through November 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
<b>October 2011:</b>					
001	Nitrogen, Ammonia (NH3)	30D Qty	.5	.69714	10/1/2011
001	Nitrogen, Ammonia (NH3)	30D Conc	1	1.90875	10/1/2011
001	Fecal Coliform	7D Conc	2000	2340.	10/15/2011
001	Nitrogen, Ammonia (NH3)	7D Qty	0.74	1.95756	10/15/2011
001	Nitrogen, Ammonia (NH3)	7D Conc	1.5	5.37	10/15/2011
001	Nitrogen, Ammonia (NH3)	7D Qty	0.74	.78527	10/22/2011
001	Nitrogen, Ammonia (NH3)	7D Conc	1.5	2.145	10/22/2011
<b>November 2011:</b>					
001	Total Suspended Solids	7D Qty	8.9	13.4045	11/1/2011
001	Total Suspended Solids	7D Conc	18	40.5	11/1/2011
001	Dissolved Oxygen	1D Conc	6.0	5.9	11/30/2011

**Notes:** 1D Conc = Daily Average Concentration Value  
1D Qty = Daily Average Loading Value  
7D Conc = Weekly Average Concentration Value  
30D Conc = Monthly Average Concentration Value  
7D Qty = Weekly Average Loading Value  
30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Also, you are reminded that you are required to report any non-compliance that is the result of any violation of a daily maximum discharge limit or due to an upset or unanticipated bypass that results in an exceedance of any effluent limitation within 24 hours of discovery by email or telephone, with a written follow-up notice within 5 days. Report all other instances of NPDES permit non-compliance on your Discharge Monitoring Report.

Please inform this office, in writing, within ten days of receipt of this notification, as to the reasons for the above-referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,

A handwritten signature in blue ink, appearing to be 'Abbot Stevenson', written over a horizontal line.

Ms. Abbot Stevenson  
Environmental Engineer  
Permits and Enforcement Section  
Division of Surface Water

AS/dh

c: Thomas Burnett, Operator of Record