



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 23, 2012

Re: Belmont County
Village of Shadyside WWTP
Notice of Violation
NPDES Permit 0PC00009*ED
Correspondence (PWW)

Board of Public Affairs
Village of Shadyside
50 East 39th Street
Shadyside, Ohio 43947

Dear Board Members:

We have received your self-monitoring reports covering the months of January through November 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
February 2011	001	CBOD 5 day	30D Conc	25	25.475	2/1/2011
February 2011	001	CBOD 5 day	30D Qty	56.8	58.6846	2/1/2011
February 2011	001	Fecal Coliform	7D Conc	2000	5589.27	2/15/2011
February 2011	001	CBOD 5 day	7D Conc	40	44.	2/15/2011
March 2011	001	Total Suspended Solids	7D Qty	102	113.260	3/8/2011
April 2011	001	Total Suspended Solids	7D Conc	45	52.	4/1/2011
April 2011	001	Total Suspended Solids	30D Qty	68.1	79.3108	4/1/2011
April 2011	001	Total Suspended Solids	7D Qty	102	171.187	4/1/2011
April 2011	001	CBOD 5 day	30D Qty	56.8	65.3806	4/1/2011
April 2011	001	CBOD 5 day	7D Qty	90.8	98.6545	4/1/2011
May 2011	001	Fecal Coliform	7D Conc	400	2395.82	5/15/2011
June 2011	001	CBOD 5 day	30D Conc	25	43.2222	6/1/2011
June 2011	001	CBOD 5 day	7D Conc	40	46.	6/1/2011
June 2011	001	CBOD 5 day	30D Qty	56.8	70.9754	6/1/2011
June 2011	001	CBOD 5 day	7D Conc	40	43.	6/8/2011
June 2011	001	CBOD 5 day	7D Conc	40	71.5	6/15/2011
June 2011	001	CBOD 5 day	7D Qty	90.8	117.565	6/15/2011
July 2011	001	Fecal Coliform	7D Conc	400	1759.54	7/15/2011
September 2011	001	Fecal Coliform	7D Conc	400	1139.60	9/15/2011

Notes: 1D Conc = Daily Maximum Concentration Value
1D Qty = Daily Maximum Loading Value
7D Conc = Weekly Average Concentration Value
30D Conc = Monthly Average Concentration Value
7D Qty = Weekly Average Loading Value
30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

I have reviewed your report addressing the reasons for the above violations. I understand your facility was undergoing a major upgrade during this time period and that although every effort was made to provide the best treatment possible, these violations occurred. Further, the construction project is complete and any construction related violations should cease. No additional information is requested at this time.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh

c: Doug Beekman, Superintendent