



**Environmental Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 23, 2012

**Re:** Athens County  
Cool Spot Convenience Store  
SNC Notice of Violation  
NPDES Permit 0PR00127\*CD  
Correspondence (PWW)

Mr. Bryan White  
25780 Brimstone Road  
Coolville, Ohio 45723

Dear Mr. White:

We have received your self-monitoring reports covering the months of March through November 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
<b>March 2011:</b>						
001	00530	Total Suspended Solids	30D Conc	12	20.	3/1/2011
001	00530	Total Suspended Solids	1D Conc	18	20.	3/9/2011
<b>June 2011:</b>						
001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.0	1.39	6/1/2011
<b>July 2011:</b>						
001	31616	Fecal Coliform	30D Conc	1000	7000.	7/1/2011
001	31616	Fecal Coliform	1D Conc	2000	7000.	7/13/2011
<b>November 2011:</b>						
001	00530	Total Suspended Solids	30D Conc	12	24.	11/1/2011
001	00530	Total Suspended Solids	1D Conc	18	24.	11/9/2011

**Notes:** 1D Conc = Daily Average Concentration Value  
1D Qty = Daily Average Loading Value  
7D Conc = Weekly Average Concentration Value  
30D Conc = Monthly Average Concentration Value  
7D Qty = Weekly Average Loading Value  
30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have received your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. **Additional action is required for you to assure us that you can return to consistent compliance with your NPDES permit. Please provide a plan of action with a timetable identifying steps that will be taken to return to consistent compliance, within 30 days of receipt of this notice of violation.** Also, there is currently no operator of record listed for your facility in our records. Please return the enclosed form to the address at the top as soon as possible.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Abbott Stevenson', with a long horizontal flourish extending to the right.

Ms. Abbot Stevenson  
Environmental Engineer  
Permits and Enforcement Section  
Division of Surface Water

AS/dh

c: Victor Reverendo, DSW, CO