



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 23, 2012

Re: Athens County
Spreading Oaks MHP
Notice of Violation
NPDES Permit 0PV00001*FD
Correspondence (PWW)

Mr. Jeff Yorick, VP Engineering
UMH Properties
1275 Forman Drive
Morgantown, WV 26508

Dear Mr. Yorick:

We have received your self-monitoring reports covering the months of July through November 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	1D Qty	2.05	2.66843	10/20/2011


Notes: 1D Conc = Daily Average Concentration Value
1D Qty = Daily Average Loading Value
7D Conc = Weekly Average Concentration Value
30D Conc = Monthly Average Concentration Value
7D Qty = Weekly Average Loading Value
30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

If you have any questions or comments, please contact me at (740) 380-5284.

Sincerely,



Abbot Stevenson
Environmental Engineer
Permits and Compliance Section
Division of Surface Water

AS/dh

- c: Paul Brooks, Spreading Oaks Village MHP
- c: Rick Verhotz, Stantec Consulting