



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 23, 2012

Re: Athens County
Health Recovery Services
Bassett House & Women's Ctr.
Notice of Violation
NPDES Permit 0PX00008*CD
Correspondence (PWW)

Mr. Rich Green
Health Recovery Services, Inc.
P.O. Box 724
Athens, Ohio 45701

Dear Mr. Green:

We have received your self-monitoring report covering the months of July through November 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
July 2011:						
001	80082	CBOD 5 day	30D Conc	10	47.7	7/1/2011
001	80082	CBOD 5 day	30D Qty	0.09	.27984	7/1/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	4.5	7/11/2011
001	80082	CBOD 5 day	1D Conc	15	75.4	7/18/2011
001	80082	CBOD 5 day	1D Qty	0.14	.44235	7/18/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	27.8	7/20/2011
002	50060	Chlorine, Total Residual	1D Conc	0.019	1.	7/21/2011
001	80082	CBOD 5 day	1D Conc	15	20.	7/26/2011
August 2011:						
002	50060	Chlorine, Total Residual	1D Conc	0.019	1.	8/10/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.95	8/24/2011
September 2011:						
002	00530	Total Suspended Solids	30D Conc	12	13.	9/1/2011
October 2011:						
001	31616	Fecal Coliform	30D Conc	1000	3925.77	10/1/2011
001	31616	Fecal Coliform	1D Conc	2000	3233.	10/5/2011
001	31616	Fecal Coliform	1D Conc	2000	4767.	10/19/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.13	10/19/2011
002	50060	Chlorine, Total Residual	1D Conc	0.019	.32	10/19/2011

Notes: 1D Conc = Daily Average Concentration Value
1D Qty = Daily Average Loading Value
7D Conc = Weekly Average Concentration Value
30D Conc = Monthly Average Concentration Value
7D Qty = Weekly Average Loading Value
30D Qty = Monthly Average Loading Value

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Also, you are reminded that you are required to report any non-compliance that is the result of any violation of a daily maximum discharge limit or due to an upset or unanticipated bypass that results in an exceedance of any effluent limitation within 24 hours of discovery by email or telephone, with a written follow-up notice within 5 days. Report all other instances of NPDES permit non-compliance on your Discharge Monitoring Report.

If you have not already done so, please inform this office, in writing, within ten days of receipt of this notification, as to the reasons for the above-referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include the dates, either actual or proposed, for completion of the actions.

If there are any questions, please contact me at (740) 380-5284.

Sincerely,



Ms. Abbot Stevenson
Environmental Engineer
Permits and Enforcement Section
Division of Surface Water

AS/dh

c: Patsy Bail, Admin. Coord., Health Recovery Services
c: Rick Smith, DSW, CO