Ohio | Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 17, 2012

Tom Prues
Hamilton County Park District
10245 Winton Road
Cincinnati, Ohio 45231

RE: Shawnee Lookout WWTP
NPDES Permit 1PG00084*DD, OH0023752
Notice of Violation

Dear Mr. Prues:

I have conducted a compliance review of this permit for the past 6 months. My review indicates several violations of the conditions of the NPDES permit for the facility. The specific instances of non-compliance are as follows:

EFFLUENT LIMIT VIOLATIONS AT OUTFALL 1PG00084001

Parameter	Date	Permit Limit	Value Reported
CBOD 5day	6/1/2011	0.137 kg/d	0.1567 kg/d
CBOD 5day	6/1/2011	10 mg/l	45 mg/l
Fecal Coliform	6/1/2011	1000 counts	2700 counts
pH	6/15/2011	9.0 S.U.	9.1 S.U.
Fecal Coliform	6/22/2011	1000 counts	2700 counts
CBOD 5day	6/22/2011	15 mg/l	45 mg/l
Nitrogen, Ammonia	8/1/2011	1.0 mg/l	9.5 mg/l
Nitrogen, Ammonia	8/1/2011	0.0137 kg/d	0.02733 kg/d
T. Susp. Solids	11/1/2011	0.164 kg/d	2.97032 kg/d
Nitrogen, Ammonia	11/1/2011	0.0409 kg/d	0.35644 kg/d
T. Susp. Solids	11/8/2011	0.246 kg/d	2.97032 kg/d
Nitrogen, Ammonia	11/8/2011	0.0614 kg/d	0.35644 kg/d

Southwest District Office
401 East Fifth Street
Dayton, OH 45402-2911

937 | 285 6357
937 | 285 6249 (fax)
www.epa.ohio.gov

As required under the permit, non-compliance notifications were sent to this agency regarding the above violations. No further response is necessary.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111. If you have any questions about this letter, please contact me at (937) 285-6101.

Sincerely,

Mary Osika
Environmental Specialist
Division of Surface Water