



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

January 27, 2012

RE: Holmes County
Hardy Township
New Pointe Community Church-Millersburg
NPDES Permit No. OHC000003
Ohio EPA Permit No. 3GC05612*AG
Construction Storm Water Inspection

Mike Conn
New Pointe Community Church
3905 State Route 39 NW
Dover, OH 44622

Dear Mr. Conn:

On January 5, 2012, Ohio EPA conducted an inspection of New Pointe Community Church - Millersburg, located 250 feet east of intersection of State Route 39 and Township Road 301, Hardy Township, Holmes County (site). The site was represented by Abe Yoder, Project Manager, of Ivan Weaver Construction. Ohio EPA records indicate that the site is covered by General National Pollutant Discharge Elimination System Permit for Storm Water Associated with Construction Activity (General Storm Water Permit), permit No. 3GC05612*AG. The inspection documented the following violations:

Storm Water Inspection

- No sediment controls (i.e. silt fence) has been installed along the eastern and western property boundaries. Sediment deposition was observed on a neighboring property and immediately adjacent to an onsite stream. Silt fence must be properly installed on the eastern and western portions of the site that do not drain to the sediment settling pond.
- The site has not been winter stabilized. All idle areas must be stabilized with mulch to prevent erosion from occurring.

According to the site's storm water pollution prevention plan (SWP3), 337 feet of intermittent stream and 0.059 acres of wetlands are to be impacted. Please provide copies of any authorization that was issued by the U.S. Army Corps of Engineers for these impacts.

In accordance with Part III.C.2 of the General Storm Water Permit, please submit a copy of the site's SWP3, including information (i.e. design calculation, water quality volume calculation, outlet structure design, etc.) regarding the post-construction storm water management best management practices, and the site's post construction operation and maintenance plan. This information must be submitted to Ohio EPA within ten (10) days of receiving this correspondence.

NEW POINTE COMMUNITY CHURCH-MILLERSBURG
JANUARY 27, 2012
PAGE 2 OF 2

Should you have any questions regarding this matter, please contact me at your earliest convenience at (330) 963-1118 or via e-mail at chris.moody@epa.ohio.gov.

Sincerely,



Chris Moody
Environmental Specialist II
Division of Surface Water

CM/cs

cc: Mark Weaver, Ivan Weaver Construction
Shaffer, Johnston, Lichtenwall and Associates