



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Erie County  
Sunset Grill  
NPDES Permit

January 31, 2012

Mr. Dan Decker, Owner  
Sunset Grill  
2812 Cleveland Road E  
Huron, Ohio 44839

Dear Mr. Decker:

On September 8, 2011, an inspection was made of the wastewater treatment plant serving the Sunset Grill. In general, both operation and maintenance was fair. At the time of my visit, the plant's timer was in the "off" mode; however, I observed a clear effluent in the chlorine contact tank. The surface sand filters were being maintained and disinfection and dechlorination tablets were present in the tube feeders.

Discharge monitoring reports are being received in a timely manner, and a review indicates improved compliance, with only two violations during 2011.

Enclosed is my inspection report. If you have any questions, please call me at (419) 373-3020, or email at [rick.zuzik@epa.state.oh.us](mailto:rick.zuzik@epa.state.oh.us).

Sincerely,

Richard A. Zuzik, MSE  
Division of Surface Water

/jlm

Enclosures

pc: Erie County Health Department  
Eastwood Environmental

ec: Inspection Tracking

OHIO ENVIRONMENTAL PROTECTION AGENCY

OPERATION AND MAINTENANCE INSPECTION  
 WWTP'S LESS THAN 25,000 GPD

NPDES Permit No. 2PR00085\*CD

Facility Name Sunset Grill Expiration Date 12-31-13

Facility Address 2812 Cleveland Rd, E Date \_\_\_\_\_ Time \_\_\_\_\_ am / pm

City \_\_\_\_\_ County Erie Township Berlin

Name and Address of Owner Dan Decker

Person Contacted none Owner Phone (419) 656-4765

Flow: Design 1500 GPD Present \_\_\_\_\_ GPD (metered - estimated)

Trib. Pop. small bar/food service (actual - estimated) Weather at time of inspection: Temp 60° Clear

OEPA Personnel Rick Zuzik District NWDO

1. Plant Effluent - Mark Severity No.

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None		Clear		None		Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

2. Effect of effluent on Receiving Stream Name: Catch Basin to Lake Erie

No.	Severity Description	No.	Turbidity	No.	Odor	No.	Color
0	None		Clear		None		Colorless
1	Mild						
2	Moderate		Light Solids		Musty		Grey
3	Serious						
4	Extreme		Heavy Solids		Septic		Black

3. a. Plant has \_\_\_\_\_ excellent \_\_\_\_\_ good ✓ fair \_\_\_\_\_ poor operation  
 b. Plant has \_\_\_\_\_ excellent \_\_\_\_\_ good ✓ fair \_\_\_\_\_ poor maintenance  
 c. Sand filters have \_\_\_\_\_ excellent \_\_\_\_\_ good ✓ fair \_\_\_\_\_ poor maintenance

d. Not operating at expected efficiency due to:

- (1) \_\_\_\_\_ hydraulic overload  
 (2) \_\_\_\_\_ organic/ solids overload  
 (3) \_\_\_\_\_ personnel inefficiency  
 (4) \_\_\_\_\_ equipment failure  
 (5) \_\_\_\_\_ wastes  
 (6) \_\_\_\_\_

Disinfection: (Required May 1 thru Oct.31.)

IN <u>✓</u>	OUT _____	Chlorination Tablets
_____	_____	Dechlorination Tablets
_____	_____	U.V.

Yes No (1/11 - 12/11)

records on-site ✓

4. \_\_\_\_\_ Compliance with NPDES Permit

Periodic Violations Y N Parameters: TSS, BOD5

Chronic Violations \_\_\_\_\_

5. ✓ Adequate plant safety

6. ✓ Operation and Maintenance Service Name Castwood Env.

Frequency of Visits \_\_\_\_\_

Facility Name: Sunset Grill

Process	# Units	Unit	If Needed - Description and Comments
Preliminary	<del>1</del>	Trash Trap	Pumping Frequency:
		Grease Trap	Pumping Frequency:
		Bar Screen	
		Comminutor	
		Flow Equalization	
Aeration Equipment		Plant Timer <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	Cycle Time: 10 "off" mode ATOL
	<del>1</del>	Motor/ Blower Unit	
Secondary Treatment	1	Aeration Tank	Color: Adequate Aeration: Y <input type="checkbox"/> N <input type="checkbox"/>
Final Settling	1	Clarifier	
	1	Sludge Return	In _____ Out _____
	1	Surface Skimmer	In _____ Out _____
		Fixed Media Clarifier	
Tertiary Treatment	2	Surface Sand Filter	OK
		Polishing Pond	
		Other	
Disinfection	1	Contact Tank	clear effluent
	1	Chlorine Tube Feeder	IN
	1	Dechlorination Tube Feeder	IN
		Ultraviolet (UV)	
Flow Metering		Elapsed Pump Time	
		Recorder (continuous total)	
Pumps		Raw Wastewater (type)	
		Sand Filter Effluent Dosing	
Sludge Handling		Aerated Storage Tank	
		Sludge Drying Bed	
Sludge Disposal	<del>1</del>	Municipal POTW	
		Landfill	
		Land Application	
Advanced Treatment		Post Aeration	
		Spray Irrigation	
		Other	