



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 31, 2012

Craig Goodwin
Plaza Properties
3016 Maryland Avenue
Columbus, OH 43209

Re: **Construction Storm Water Inspection at Plaza Development
Licking County
Permit #: 4GC03605*AG (SECOND NOTICE)**

Dear Mr. Goodwin:

This letter is written regarding a storm water inspection I conducted at Plaza Development located at US 62 west of Westville Drive Johnstown, Ohio on January 24, 2012 in follow up to my previous inspection on December 28, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, I staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Controls:

- It appears fine grading is complete for this site. **I noted portions of the site have been stabilized, however, additional control measures are expected to full protect this site from erosion, specifically the fill slopes. Given the time of year, a crimped straw mulch cover or equivalent is expected.**

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. .

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Plaza Development 1-24-2012