



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 31, 2012

Chuck Dilbone
Granville Exempted Village School
130 N Granger Street
Granville, OH 43023

**Re: Construction Storm Water Inspection at Granville Intermediate School
Permit Number: 4GC03629*AG**

Dear Mr. Dilbone:

This letter is written regarding a storm water inspection I conducted at Granville Intermediate School located at 2025 Burg Avenue, Granville, Ohio on January 23, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

- Establish a successful vegetative cover sufficient to control erosion measured by a minimum density of 70 percent.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Granville Intermediate School 1-23-2012