



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

RE: Notice of Violation  
Wood County  
Stormwater  
Construction Activity  
Permit No. 2GC01082\*AG

February 2, 2012

Pastor Jerry Hunt  
Word of Truth Christian Center  
1163 Napoleon Road  
Bowling Green, Ohio 43402

Dear Pastor Hunt:

On January 25, 2012, I performed an inspection of the construction site for the Word of Truth Christian Center located at 1163 Napoleon Road in Bowling Green, Wood County. The purpose of this visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity also known as the Construction General Permit (CGP). The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

As a result of the inspection, I have the following comments/observations:

1. At the time of the inspection, all construction appeared to be complete.
2. The area to the south and west of the building is at grade but had not been stabilized. *This is a violation of Part III.G.2.b. of the CGP which requires stabilization of any area that will remain undisturbed for 21 days or remain idle over winter*

Within 15 days of the date on this letter, please submit to this office **written notification** of the actions taken or proposed to prevent any future violations. Your response should include the dates, either actual or proposed, for the completion of the actions.

If you have any questions, you may contact me by e-mail at [patricia.tebbe@epa.state.oh.us](mailto:patricia.tebbe@epa.state.oh.us) or by phone at (419) 373-3016.

Sincerely,

Patricia A. Tebbe, P.E.  
Division of Surface Water

/jlm

pc: Brian O'Connell, P.E., City of Bowling Green  
ec: Inspection Tracking