



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Notice of Violation  
Wood County  
Unnamed Restaurant  
Stormwater Construction  
Permit No. 2GC02946AG

February 2, 2012

Mr. Bradley E. Mangas  
BE Mangas Construction Inc.  
28611 State Route 281  
Defiance, Ohio 43512

Dear Mr. Mangas:

On January 25, 2012, I performed an inspection of the construction site for an unnamed restaurant located at 1550 East Wooster Street, Bowling Green, Ohio, Wood County. The purpose of this visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity also known as the Construction General Permit (CGP). The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

As a result of the inspection, I have the following comments/observations:

1. At the time of the inspection, construction was ongoing. This construction site is a redevelopment site.
2. At the time of the inspection, the Storm Water Pollution Prevention Plan (SWP3) and inspection logs were not reviewed.
3. The catch basin located in the drainage swale had a silt fence barrier around it that was falling down. *This is a violation of Part V.N. of the CGP, which requires proper operation and maintenance of all systems of treatment and control.*
4. There were two unprotected catch basins on the west side of the site. *This is a violation of Part III.G.2.d.iv. of the CGP, which requires inlet protection.*

Within 15 days of the date on this letter, please submit to this office **written notification** of the actions taken or proposed to prevent any future violations. Your response should include the dates, either actual or proposed, for the completion of the actions.

If you have any questions, you may contact me by e-mail at [patricia.tebbe@epa.state.oh.us](mailto:patricia.tebbe@epa.state.oh.us) or by phone at (419) 373-3016.

Sincerely,



Patricia A. Tebbe, P.E.

Division of Surface Water

/jlm  
pc: Brian O'Connell, P.E., City of Bowling Green  
ec: Inspection Tracking

Northwest District Office  
347 North Dunbridge Road  
Bowling Green, OH 43402-9398

419 | 352 8461  
419 | 352 8468 (fax)  
[www.epa.ohio.gov](http://www.epa.ohio.gov)