



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Notice of Violation
Wood County
First Federal Bank
Stormwater Construction
Permit No. 2GC02952AG

February 2, 2012

Mr. John Boesling
First Federal Bank
601 Clinton Street
P.O. Box 248
Defiance, Ohio 43512

Dear Mr. Boesling:

On January 25, 2012, I performed an inspection of the construction site for the First Federal Bank located at 1200 North Main Street, Bowling Green, Ohio, Wood County. The purpose of this visit was to evaluate compliance of the site with the National Pollutant Discharge Elimination System (NPDES) permit for storm water discharges associated with construction activity also known as the Construction General Permit (CGP). The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

As a result of the inspection, I have the following comments/observations:

1. At the time of the inspection, construction was ongoing.
2. At the time of the inspection, the Storm Water Pollution Prevention Plan (SWP3) and inspection logs were not reviewed.
3. Silt fence has not been maintained around the dirt stockpile. *This is a violation of Part V.N. of the CGP, which requires proper operation and maintenance of all systems of treatment and control.*

There are no co-permittees listed for this project. Within 15 days of the date on this letter, please submit to this office **written notification** of the actions taken or proposed to prevent any future violations. Your response should include the dates, either actual or proposed, for the completion of the actions.

If you have any questions, you may contact me by e-mail at patricia.tebbe@epa.state.oh.us or by phone at (419) 373-3016.

Sincerely,

Patricia A. Tebbe, P.E.
Division of Surface Water

/jlm

pc: Brian O'Connell, P.E., City of Bowling Green

ec: Inspection Tracking