



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Notice of Violation
Fulton County
Village of Metamora
NPDES Permit

February 2, 2012

Mr. Rick Meiring
WWTP Superintendent
Village of Metamora
P.O. Box 299
Metamora, Ohio 43540

Dear Mr. Meiring:

This letter is in regard to the January 25, 2012, inspection of the Village of Metamora's wastewater treatment plant (WWTP). Mr. Chip Vance was present and provided information on operation and maintenance of treatment plant. The lagoon was discharging during the inspection. The discharge observed at Ten Mile Creek had a light green color with no noticeable odor.

It is noted that a Permit to Install (PTI) has been submitted for the as built Solar Bee unit in lagoon number 2 and for the fine air bubbler system in the final discharge lagoon. We have provided comments on the PTI and are awaiting revisions to move forward with the approval process.

A review of the discharge monitoring reports (DMRs) from August 2011 to January 2012 shows that there has been one NPDES permit effluent limit violation. The specific instance of non-compliance is enclosed on a separate sheet.

If you have any questions or comments, please contact me at (419) 373 – 3053.

Sincerely,

Ryan Gierhart
Division of Surface Water

/jlm

Enclosures

pc: Mayor and Council
ec: Inspection Tracking

Get New Data								
Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00065*FD	September 2011	001	00400	pH	1D Conc	9.0	9.02	9/13/2011