



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

February 1, 2012

RE: STARK COUNTY
VILLAGE OF BREWSTER WWTP
NPDES 3PB00006
2012 CEI

Mayor and Council
Village of Brewster
302 South Wabash
Brewster, OH 44613

Dear Mayor and Council:

On January 19, 2012, this office conducted a compliance evaluation inspection (CEI) of The Village of Brewster Wastewater Treatment Plant (WWTP).

At the time of the inspection, the WWTP was in good operation and maintenance condition. The mixed liquor in the aeration tank had a good color and was provided with good air circulation. No solids were passing over the weirs in the clarifier and the chlorine contact tank was currently not in use. Overall, the treatment system was producing a clear effluent that appeared to be of satisfactory quality.

A review of your Discharge Monitoring Reports (DMRs) covering the period June 2010 through December 2011 revealed the following effluent violations:

Permit No	Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
3PB00006*HD	June 2010	001	Phosphorus, Total (P)	30D Conc	1.0	1.79	6/1/2010
3PB00006*HD	June 2010	001	Phosphorus, Total (P)	30D Qty	2.5	3.77376	6/1/2010
3PB00006*HD	June 2010	001	Phosphorus, Total (P)	7D Conc	1.5	1.79	6/15/2010
3PB00006*HD	July 2010	001	Phosphorus, Total (P)	30D Conc	1.0	1.78	7/1/2010
3PB00006*HD	July 2010	001	Phosphorus, Total (P)	7D Conc	1.5	1.78	7/8/2010
3PB00006*HD	May 2011	001	Phosphorus, Total (P)	30D Qty	2.5	2.89524	5/1/2011


New water quality standards were adopted by Ohio EPA. These rules require changes to be made to the bacteria monitoring and limits in all new and renewed National Pollutant Discharge Elimination System (NPDES) permits. The new standards will require the implementation of E.coli limits and monitoring requirements. The E.coli standards will be stated in the renewed NPDES permit. Information regarding the new E.coli water quality standards can be found on the Ohio EPA, Division of Surface Water website: www.epa.ohio.gov/dsw.

VILLAGE OF BREWSTER WWTP
FEBRUARY 1, 2012
PAGE 2 OF 2

The renewal NPDES permit for this facility will be public noticed in the near future. You will have 30 days from the date of public notice to submit written comments to Ohio EPA regarding the draft permit.

Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Sincerely,



Todd Surrena
Engineering Geologist
Division of Surface Water

TMS/cs

cc: Mike Maybaugh, Brewster WWTP
Steve Hartman, Administrator, Village of Brewster

File: Public/Permit Compliance