



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

February 3, 2012

RE: SUMMIT COUNTY
BATH TOWNSHIP
CLEARVIEW INN STEAK & CHOP HOUSE
COMPLIANCE EVALUATION INSPECTION
NPDES NO. 3PR00360

Mr. Thomas Poinar, Owner
Parsons-Poinar Partnership
2446 N. Cleveland-Massillon Road
Akron, OH 44333

Dear Mr. Poinar:

On January 31, 2012, a routine Compliance Evaluation Inspection was conducted at the wastewater treatment plant (WWTP) serving Clearview Inn. According to our files, the existing wastewater treatment system consists of a 500-gallon trash trap, a 6000 gpd extended aeration plant with clarifier, a 253-gallon dosing chamber, a 272 square foot surface sand filter, and a chlorination/dechlorination tank. It also appears the plant contains an equalization tank. The WWTP discharges into an unnamed tributary of North Fork Yellow Creek.

During the inspection, the following observations and/or deficiencies were noted:

1. The treatment plant was running, appeared to be receiving sufficient air, and had no offensive odor. The color of the mixed liquor in the aeration tank was slightly dark in color, indicating that it may be time to waste solids from the system.
2. The clarifiers had lots of solids behind the baffles; it appears it's time to scrape down and pump out the clarifiers. The return lines appeared to be operating properly.
3. Both surface sand filter cells contained lots of vegetation which should be removed. One sand filter cell contained lots of solids which should be removed. The sand filters may need additional sand; a minimum of 18 inches is required.

Review of the electronic Discharge Monitoring Reports (DMRs) from September 2010 through January 2012 revealed the following numeric effluent violations:


Reporting Period	Parameter	Limit Type	Limit	Reported Value	Violation Date
March 2011	Total Suspended Solids	30D Conc	12	33.8	3/1/2011
March 2011	CBOD 5 day	30D Conc	10	42.1	3/1/2011
March 2011	Dissolved Oxygen	1D Conc	6.0	1.13	3/31/2011
June 2011	Fecal Coliform	30D Conc	1000	4300.	6/1/2011
June 2011	CBOD 5 day	30D Conc	10	20.2	6/1/2011
August 2011	Chlorine, Total Residu	1D Conc	0.019	.2	8/1/2011

CLEARVIEW INN STEAK & CHOP HOUSE
FEBRUARY 3, 2012
PAGE 2 OF 2

Please be advised such instances of noncompliance are subject to enforcement pursuant to Ohio Revised Code (ORC) 6111.

In conclusion, the operation and maintenance of the WWTP appeared satisfactory. This office has no major concerns at this time. If you have any questions concerning this letter, please contact this office at (330) 963-1151.

Sincerely,



Jennifer S. Bennage
Environmental Engineer
Division of Surface Water

JSB/cs

cc: Owner, Clearview Inn Steak and Chop House
Tom LaPlante, Summit County Health Dept.