



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

RE: **Notice of Violation**
Auglaize County
New Bremen WWTP
Ohio EPA Permit No. 2PB00034
NPDES Permit No. OH0020346

February 7, 2012

Mr. Jerry Fischbach
WWTP Superintendent
Village of New Bremen
P.O. Box 27
New Bremen, Ohio 45869

Dear Mr. Fischbach:

We are in receipt of your self-monitoring report covering the months of October through December 2011 for the referenced facility. Our review indicates a violation of the conditions of your NPDES permit. The specific instance of noncompliance is enclosed on a separate sheet.

We have received your email dated November 19, 2011, regarding the above referenced violations and require no further information at this time.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in your Part III-General conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. Information about Ohio EPA's Office of Compliance Assistance & Pollution Prevention can be found on Ohio EPA's Website at <http://epa.ohio.gov/ocapp> or by calling (614) 644 – 3469.

If there are any questions, please contact me at (419) 373 – 3022.

Sincerely,

Justin A. Williams
Division of Surface Water

/jlm
Enclosure
ec: Inspection Tracking

Get New Data

Violation for New Bremen WWTP - October - December 2011

| Permit No | Reporting Period | Station | Reporting Code | Parameter | Limit Type | Limit | Reported Value | Violation Date |
|-------------|------------------|---------|----------------|------------------------|------------|-------|----------------|----------------|
| 2PB00034*KD | October 2011 | 001 | 00530 | Total Suspended Solids | 7D Qty | 102.0 | 103.570 | 10/15/2011 |