



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 23, 2012

Jeff Holbrook, PE
Ohio Department of Transportation
400 East William Street
Delaware, OH 43015

RE: **I-71 and SR 665 Interchange / Franklin County
Permit #4GC03288*AG**

Dear Mr. Holbrook:

This letter is written regarding a storm water complaint that I received at Grant Run near Hoover Road, on January 9, 2012. The complaint stated that Grant Run appeared very turbid and there was no recent rain event. Your project is directly upstream of that location. I understand that your construction activities are currently covered under the General Storm Water Permit. I conducted a storm water inspection on January 11, 2012 and Grant Run was not turbid. Please see my following notes of the inspection.

Sediment and Erosion Controls:

- The barren areas of the site were being temporary stabilized with crimped straw.
- I noted erosion controls were installed at the site.
- The General Permit requires the permittee to conduct inspections of all sediment and erosion controls every seven days or within 24 hours of a rain event equal to or greater than 0.5 inches. A log of the inspections and resulting corrective actions must be maintained on site available for review.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

ec: Greg Sanders, CDO/DSW

GS/nm ODOT I71 SR665, January 9, 2012

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov