



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 25, 2012

Karl Wetherholt, PE
City of Gahanna
200 S Hamilton Road
Gahanna, OH 43230

**Re: Construction Storm Water Inspection at Techcenter/Science Boulevard Extension Franklin County
Permit Number: 4GC03521*AG**

Dear Mr. Wetherholt:

This letter is written regarding a storm water inspection I conducted at Techcenter Drive located north of the existing Science Boulevard, Gahanna, Ohio 43230 on January 19, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

It appeared during the inspection that construction activity has been completed for this site. A Notice of Termination will be required provided the post construction and stabilization requirements are met. Please address the following:

- Establish a successful vegetative cover sufficient to control erosion measured by a minimum density of 70 percent.
- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates can be found at: <http://www.epa.state.oh.us/dsw/storm/CGPPCOA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria with your submittal.
- A Notice of Termination (NOT) must be submitted once the post construction requirements are verified. The NOT form and filing instructions can be found at: <http://www.epa.state.oh.us/dsw/storm/stormform.aspx>.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO