



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 24, 2012

Matt Foor
Performance Training School
7791 Taylor Road
Pataskala, OH 43068

**Re: Construction Storm Water Inspection at Performance Training School
7791 Taylor Road, Pataskala, Ohio
Permit Number 4GC033631*AG**

Dear Mr. Foor:

This letter is written in follow-up to a construction storm water inspection I conducted at Performance Training School located at 7791 Taylor Road, in Pataskala, Ohio on January 10, 2012 in follow-up to my initial inspection on November 15, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities at this site:

Winter Rule:

- All barren and idle areas, specifically the entire site, must be protected in preparation for the upcoming winter months. Given the time of year, a crimped mulched cover, or equivalent, is expected. The area remains barren with no change from last inspection.

Sediment Controls:

- During the inspection, it appeared the site was void of effective sediment controls. It was my understanding that a centralized sediment basin would be utilized for sediment control. Please be able to ensure all affected areas are routed to the basin intended for sediment control via earthen diversions. No apparent change from last inspection.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Performance Training School 1-10-2012

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov