



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 6, 2012

Demetrius Williams
Kroger Company
4111 Executive Parkway
Westerville, OH 43081

Re: Storm Water Inspection at Kroger #839/Permit #4GC02315*AG

Dear Mr. Williams:

This letter is written regarding the storm water inspection I conducted at Kroger, located at 1177 Polaris Parkway in Delaware County, on January 30, 2012. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Post Construction Requirements:

- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://epa.ohio.gov/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.
- Please note the dry basins as noted during the inspection do NOT appear to meet the minimum requirements of the permit.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844. In addition, please provide a written response to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Kroger 839 Lewis Center 1-30-2012