



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 6, 2012

Chris Elliott
Ohio Soil Recycling, LLC
2101 Integrity Drive
Columbus, OH 43209

Re: **Construction Storm Water Inspection at Ohio Soil Recycling
Franklin County
Permit Number: 4GC03436*AG**

Dear Mr. Elliott:

This letter is written regarding a storm water inspection I conducted at Ohio Soil Recycling located at 2101 Integrity Drive, Columbus, Ohio 43209 on January 25, 2012. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Site Observations:

- Please ensure the perimeter ditch located on the north east corner of the site is graded to ensure all positive drainage to sediment pond number 1
- During the investigation, I observed the lack of posi-shell protection on the large stockpile. Please take corrective measures to minimize the erosion from these areas.
- Please continue to relocate all contaminated soils onto the treatment pad

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response (**email preferred**) to the action items addressed above within ten days from receipt of this letter. A follow-up inspection will be conducted to ensure the minimum conditions of the General Permit have been met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

Enclosures

HK/nsm Ohio Soil Recycling

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov