



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 6, 2012

Tucker Bohm
Daimler Group
1533 Lake Shore Drive
Columbus, OH 43204

**Re: Construction Storm Water Inspection at Water's Edge Phase 2
Franklin County
Permit Number: 4GC03501 *AG**

Dear Mr. Bohm:

This letter is written regarding a storm water inspection I conducted at Water's Edge located at 7795 Walton Parkway New Albany, Ohio on January 25, 2011. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The majority of the site is routed to a basin intended for sediment control. Please ensure proper maintenance of the basin and remove all sediment once 50 percent of the capacity is exceeded.
- The large stockpile on the east portion of the site must be protected from erosion. Given the time of year a crimped mulch cover or equivalent is expected.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Water's Edge Phase 2 1-25-2012