



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 13, 2012

Mayor & Council
City of Hillsboro
130 North High Street
Hillsboro, OH 45133

**Re: Hillsboro WWTP – 1PC00100*ID
Notice of Violation**

Dear Permittee:

A compliance review was conducted on your Discharge Monitoring Report (DMR) submitted on **2/9/2012**. As detailed at the end of this letter, screening of your submitted DMR has identified compliance issues.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES Permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. No additional information is requested at this time. Future violations must continue to be reported as required by the NPDES Permit as detailed in Part III.12 titled "Non-compliance Notification".

If you should have any questions, feel free to contact me by phone at (937) 285-6029 or by electronic mail at Joshua.Jackson@epa.state.oh.us.

Respectfully,

Joshua Jackson
Environmental Specialist II
Division of Surface Water

JJ/tf

ec: bleeth@hillsboroohio.net



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Notice of Violation Report

Facility: Hillsboro WWTP

Permit No.: 1PC00100*ID

Report Period: January 2012

Date Received: 2/9/2012

Station	Type	Date	Reporting Code	Parameter	Limit Type	Permit Limit	Reported Value
001	Limit	1/22/2012	00530	Total Suspended Solids	Weekly Load	118.2	142.350
001	Limit	1/22/2012	00665	Phosphorus, Total (P)	Weekly Load	6.8	7.50345