



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

February 10, 2012

RE: STARK COUNTY
SUGAR CREEK TOWNSHIP
COUNTRY LAWN NURSING CENTER
10608 NAVARRE ROAD
NPDES #3PR00269

Mr. David Notman
Director of Maintenance
Country Lawn Nursing Center
10608 Navarre Road SW
Navarre, Ohio 44662

Dear Mr. Notman:

A compliance evaluation inspection of the sewage treatment plant serving the Country Lawn Nursing Center was conducted by this writer on February 3, 2012. The treatment plant consists of a trash trap, flow equalization tank, extended aeration tank, dosing chamber, surface sand filters, chlorination/dechlorination system, and aerated sludge holding tank. The system discharges to an unnamed tributary of the Tuscarawas River.

At the time of the inspection, the treatment plant was in good operation. The mixed liquor in the aeration tank had a good color and the settling tank effluent was clear. No solids were noted in the chlorine tank and the system was producing what appeared to be a satisfactory quality effluent.

A review of your self-monitoring reports covering the period January 1, 2011 through December 31, 2011 revealed the following effluent violations:

Limit Violations

Permit No	Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
3PR00269*CD	July 2011	001	CBOD 5 day	30D Conc	10	15.	7/1/2011

Frequency Violations

Permit No	Reporting Period	Station	Parameter	Sample Frequency	Expected	Reported	Violation Date
3PR00269*CD	March 2011	001	Water Temperature	1/Week	1	0	03/15/2011
3PR00269*CD	March 2011	001	Dissolved Oxygen	1/Week	1	0	03/15/2011
3PR00269*CD	April 2011	001	pH	1/2Weeks	1	0	04/01/2011
3PR00269*CD	July 2011	001	Chlorine, Total Residu	1/2Weeks	1	0	07/01/2011

COUNTRY LAWN NURSING CENTER
FEBRUARY 10, 2012
PAGE 2 OF 2

Overall, the results of the inspection were satisfactory. Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Sincerely,

A handwritten signature in black ink, appearing to read "Todd Surrena". The signature is fluid and cursive, with a long horizontal stroke at the end.

Todd Surrena
Engineering Geologist
Division of Surface Water

TMS/ cs

cc: Todd Ascani, Stark County Health Department

File: Semi-Public/Stark County/ Sugar Creek Township/ Country Lawn Nursing Center