



**Environmental
Protection Agency**

John R. Kasich, Governor

Mary Taylor, Lt. Governor

Scott J. Nally, Director

February 10, 2012

RE: WAYNE COUNTY
WOOSTER TWP
FORREST VIEW MHP
NPDES NO. 3PV00125

Mr. Bernie Caldwell
Owner
P.O. Box 1824
Wooster, OH 44691

Dear Mr. Caldwell:

A compliance evaluation inspection of the waste water treatment plant (WWTP) serving the Forrest View Mobile Home Park was conducted by this writer on February 2, 2012. Representing Forrest View Mobile Home Park during the inspection was Rick Jackson, WWTP operator.

The WWTP was installed under a permit-to-install (PTI) issued by Ohio EPA on December 27, 2006. The 12,000-gallon per day plant consists of a flow EQ tank, trash trap, extended aeration tanks, clarifier, dosing station, two surface sand filters, chlorination and dechlorination, and a 2,500-gallon sludge holding tank. The system discharges to unnamed tributary of Apple Creek.

At the time of the inspection, the treatment plant was in good operation. There was good air flow into the aeration tanks, sludge return lines were operating, the clarifier weirs were clean, and the dosing pumps were operating. The sand filter beds contained some solids and debris. The sand filter beds need to be racked and if needed additional sand added. The treatment system was producing what appeared to be a satisfactory effluent.

A review of your discharge monitoring reports covering the period September 1, 2011 through December 31, 2011 revealed the following effluent violations:

Permit No	Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
3PV00125*AD	September 2011	001	Fecal Coliform	30D Conc	1000	6600.	9/1/2011
3PV00125*AD	September 2011	001	Fecal Coliform	1D Conc	2000	6600.	9/8/2011
3PV00125*AD	October 2011	001	Fecal Coliform	30D Conc	1000	5600.	10/1/2011
3PV00125*AD	October 2011	001	Fecal Coliform	1D Conc	2000	5600.	10/20/2011

The renewal NPDES permit for this facility will be public noticed in the near future. You will have 30 days from the date of public notice to submit written comments to Ohio EPA regarding the draft permit.

FORREST VIEW MHP
FEBRUARY 10, 2012
PAGE 2 OF 2

Overall, the results of the inspection were satisfactory. Should you have any questions or comments regarding this letter, please contact this office at (330) 963-1255.

Respectfully,



Todd Surrena
Engineering Geologist
Division of Surface Water

TMS/ cs

cc: Wayne County Health Department
Rick Jackson, Operator

File: Semi-Public/Wayne/Wooster Twp/Forrest View MHP