



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 15, 2012

Re: Guernsey County
Island Aseptics, LLC
Notice of Violation
0IH00025; OH0076732
Correspondence (IWW)

Mr. Tom Szymaniak, Plant Manager
Island Aseptics, LLC
100 Hope Road
Byesville, Ohio 43723

Dear Mr. Szymaniak:

We have received your self-monitoring reports covering the months of July 2010 through December 2011 for the Island Aseptics non-contact cooling water discharge. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	00310	BOD	8/1/2010	30D Conc	150	255.
001	00310	BOD	8/4/2010	1D Conc	200	458.
001	00310	BOD	8/11/2010	1D Conc	200	404.
November 2010:						
001	00530	Total Suspended Solids	11/1/2010	30D Conc	150	154.666
001	00530	Total Suspended Solids	11/3/2010	1D Conc	200	331.
January 2011:						
001	00310	BOD	1/1/2011	30D Conc	150	368.5
001	00530	Total Suspended Solids	1/1/2011	30D Conc	150	274.75
001	00310	BOD	1/5/2011	1D Conc	200	227.
001	00310	BOD	1/26/2011	1D Conc	200	1173.
001	00530	Total Suspended Solids	1/26/2011	1D Conc	200	840.
February 2011:						
001	00530	Total Suspended Solids	2/1/2011	30D Conc	150	154.25
001	00530	Total Suspended Solids	2/16/2011	1D Conc	200	214.

* 1D Conc is equal to the daily maximum concentration limit.
30D Conc is equal to the monthly average concentration limit.

Frequency Violations:

Station	Reporting Code	Parameter	Sampling Frequency	Violation Date	Expected	Reported
001	00550	Oil and Grease, Total	3/1/2011	1/Quarter	1	0

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,



Tim Fulks
District Representative
Division of Surface Water

TF/dh

c: Eric Phillips, Contract Operator, Envirotec Environmental Engineering