



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 15, 2012

Re: Guernsey County
Senecaville WWTP
Notice of Violation
OPA00089; OH0041548
Correspondence (PWW)

Mayor and Council
Village of Senecaville
P.O. Box 5
Senecaville, Ohio 43780

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of July 2010 through December 2011 for the Village of Senecaville’s wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	80082	CBOD 5 day	2/1/2011	30D Conc	25	29.25
April 2011:						
001	80082	CBOD 5 day	4/1/2011	30D Conc	25	32.

* 30D Conc is equal to the monthly average concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for

enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

A handwritten signature in blue ink, appearing to read "Tim Fulks".

Tim Fulks
District Representative
Division of Surface Water

TF/dh

c: Matt Stiers, Operator