



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 15, 2012

Re: Guernsey County
Byesville WWTP
Notice of Violation
0PB00004; OH0024287
Correspondence (PWW)

Mayor and Council
Village of Byesville
221 East Main Street, P.O. Box 8
Byesville, Ohio 43723

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of August 2010 through December 2011 for the Byesville wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Limit Type*	Limit	Reported Value	Violation Date
001	80082	CBOD 5 day	7D Conc	40	43.	11/1/2010
001	00552	Oil and Grease	1D Conc	10	39.	11/3/2010
February 2011:						
001	00530	Total Suspended Solids	30D Qty	56.8	72.4803	2/1/2011
001	00530	Total Suspended Solids	7D Qty	85.2	115.101	2/1/2011
April 2011:						
001	00530	Total Suspended Solids	30D Qty	56.8	82.0339	4/1/2011
001	00530	Total Suspended Solids	7D Qty	85.2	112.603	4/22/2011

* 1D Conc is equal to the Daily Maximum concentration limit.
7D Conc is equal to the weekly average concentration limit.
7D Qty is equal to the weekly average loading limit.
30D Qty is equal to the monthly average loading limit

Frequency Violations:

Station	Reporting Code	Parameter	Sampling Frequency	Expected	Reported	Violation Date
601	00530	Total Suspended Solids	2/Week	2	1	4/22/2011
601	80082	CBOD 5 day	2/Week	2	1	4/22/2011
001	00530	Total Suspended Solids	2/Week	2	1	4/22/2011
001	00610	Nitrogen, Ammonia	2/Week	2	1	4/22/2011
001	80082	CBOD 5 day	2/Week	2	1	4/22/2011

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,



Tim Fulks
District Representative
Division of Surface Water

TF/dh

c: Thomas McVicker, Superintendent