



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 16, 2012

Re: Guernsey County
Salt Fork State Park
Notice of Violation
OPP00027; OH0037851
Correspondence (PWW)

Mr. Chuck Ainsco
ODNR, Salt Fork State Park
14755 Cadiz Road
Lore City, Ohio 43755

Dear Mr. Ainsco:

We have received your self-monitoring reports covering the months of July 2010 through December 2011 for the Salt Fork State Park Lodge and Cabins WWTP. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	50060	Chlorine, Total Residual	8/6/2010	1D Conc	0.011	.05
September 2010:						
001	31616	Fecal Coliform	9/1/2010	30D Conc	1000	2942.
001	31616	Fecal Coliform	9/1/2010	7D Conc	2000	2942.
October 2010:						
001	50060	Chlorine, Total Residual	10/1/2010	1D Conc	0.011	.05
001	50060	Chlorine, Total Residual	10/3/2010	1D Conc	0.011	.05
001	50060	Chlorine, Total Residual	10/4/2010	1D Conc	0.011	.05
001	80082	CBOD 5 day	10/8/2010	7D Conc	15	18.
001	50060	Chlorine, Total Residual	10/27/2010	1D Conc	0.011	.05
001	50060	Chlorine, Total Residual	10/28/2010	1D Conc	0.011	.05
June 2011:						
001	80082	CBOD 5 day	6/1/2011	30D Conc	10	10.22
001	80082	CBOD 5 day	6/1/2011	7D Conc	15	15.4
001	80082	CBOD 5 day	6/8/2011	7D Conc	15	28.7

* 1D Conc is equal to the daily maximum concentration limit.
7D Conc is equal to the weekly average concentration limit.
30D Conc is equal to the monthly average concentration limit.

Frequency Violations:

Station	Reporting Code	Parameter	Sampling Frequency	Violation Date	Expected	Reported
581	70322	Sludge Solids, Percent	12/1/2010	1/Month	1	0
December 2011:						
581	70318	Sludge Solids, Percent	12/1/2011	1/Month	1	0
581	70322	Sludge Solids, Percent	12/1/2011	1/Month	1	0
581	70316	Sludge Weight	12/1/2011	1/Month	1	0

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,



Tim Fulks
District Representative
Division of Surface Water

TF/dh

c: Tara Lee, ODNR, Division of Engineering