



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 16, 2012

Re: Guernsey County
ODOT Rest Area 5-29
Notice of Violation
OPP00057; OH0076911
Correspondence (PWW)

Mr. Terry Gregg, Operator
ODOT, District 5
P.O. Box 306
Jacksontown, Ohio 43030

Dear Mr. Gregg:

We have received your self-monitoring reports covering the months of July 2010 through December 2011 for the ODOT Rest Area facility number 5-29. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	00530	Total Suspended Solids	9/1/2010	30D Conc	12	15.
December 2010						
001	00610	Nitrogen, Ammonia	12/1/2010	30D Conc	4.0	5.4
January 2011						
001	00610	Nitrogen, Ammonia	1/1/2011	30D Conc	4.0	6.1
001	00610	Nitrogen, Ammonia	1/22/2011	7D Conc	6.0	6.1

* 7D Conc is equal to the weekly average concentration limit.
30D Conc is equal to the monthly average concentration limit.

Non-Numeric Violations:

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	31616	Fecal Coliform	9/22/2010			AB

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

A handwritten signature in blue ink, appearing to read "Tim Fulks", with a long horizontal flourish extending to the right.

Tim Fulks
District Representative
Division of Surface Water

TF/dh