



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 16, 2012

Re: Guernsey County
Eastern Alliance Living Facility
Notice of Violations
OPP00085; OH0124770
Correspondence (PWW)

Mr. Rod Hollingsworth
Eastern Alliance Council of Governments
1205 Newark Road
Zanesville, Ohio 43701

Dear Mr. Hollingsworth:

We have received your self-monitoring reports covering the months of July 2010 through December 2011 for the Eastern Alliance Living Facility. The specific instances of noncompliance and/or deficiencies are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	80082	CBOD 5 day	12/1/2010	30D Conc	10	15.
May 2011						
001	00610	Nitrogen, Ammonia	5/1/2011	30D Conc	1.0	1.3

* 30D Qty is equal to the monthly average loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

A handwritten signature in black ink, appearing to read "Tim Fulks".

Tim Fulks
District Representative
Division of Surface Water

TF/dh

c: Michael Wisecarver, Operator, Wisecarver Environmental