Ohio Environmental Protection Agency
John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 16, 2012

Re: Guernsey County
Go Mart No. 57 WWTP
Notice of Violation
0PR00089; OH0099759
Correspondence (PWW)

Mr. Mike Conant
Go Mart, Inc.
64322 Wintergreen Road
Lore City, Ohio 43755

Dear Mr. Conant:

We have received your self-monitoring reports covering the months of November 2010 through December 2011 for the Go Mart No. 57 wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Limit Type*	Limit	Reported Value	Violation Date
001	00610	Nitrogen, Ammonia	30D Conc	3.0	45.5	1/1/2011
001	00610	Nitrogen, Ammonia	30D Qty	0.057	.2678	1/1/2011
001	00610	Nitrogen, Ammonia	1D Conc	4.5	45.5	1/3/2011
001	00610	Nitrogen, Ammonia	1D Qty	0.085	.2678	1/3/2011
February 2011						
001	00610	Nitrogen, Ammonia	30D Conc	3.0	14.7	2/1/2011
001	00610	Nitrogen, Ammonia	30D Qty	0.057	.11017	2/1/2011
001	00610	Nitrogen, Ammonia	1D Conc	4.5	14.7	2/7/2011
001	00610	Nitrogen, Ammonia	1D Qty	0.085	.11017	2/7/2011
May 2011						
001	00610	Nitrogen, Ammonia	30D Conc	1.0	1.56	5/1/2011
001	00610	Nitrogen, Ammonia	1D Conc	1.5	1.56	5/2/2011
August 2011						
001	31616	Fecal Coliform	1D Conc	2000	3600.	8/1/2011
September 2011						
001	31616	Fecal Coliform			AK	9/12/2011
001	50060	Chlorine, Total Residual	1D Conc	0.019	.3	9/21/2011

* 1D Conc is equal to the Daily Maximum concentration limit.
1D Qty is equal to the daily maximum loading limit.
30D Conc is equal to the monthly average concentration limit.
30D Qty is equal to the monthly average loading limit

Southeast District Office
2195 Front Street
Logan, OH 43138-8637

740 | 385 8501
740 | 385 6490 (fax)
www.epa.ohio.gov

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

Tim Fulks
District Representative
Division of Surface Water

TF/dh