



**Environmental  
Protection Agency**

**John R. Kasich, Governor**

**Mary Taylor, Lt. Governor**

**Scott J. Nally, Director**

February 3, 2012

RE: SUMMIT COUNTY  
BATH TWP.  
OHIO MOTEL  
2250 CLEVELAND-MASSILLON ROAD  
COMPLIANCE EVALUATION INSPECTION  
NOTICE OF VIOLATION LETTER  
OHIO EPA NO. 3PR00159\*BD

Mr. Dalton Smith  
2248 N. Cleveland-Massillon Road  
P.O. Box 209  
Bath, OH 44210

**CERTIFIED MAIL**

Dear Mr. Smith:

On January 31, 2012, a routine Compliance Evaluation Inspection was conducted at the wastewater treatment plant (WWTP) serving Ohio Motel. After the inspection, this office spoke with Mr. Mike Humenik on-site.

According to our files, the wastewater treatment system consists of a 1000-gallon trash trap, a 4040 gpd extended aeration treatment plant, a 327-gallon dosing chamber, a 336 square foot surface sand filter, and a chlorination/dechlorination tank. The plant discharges into an unnamed tributary of North Fork of Yellow Creek.

During the inspection the following observations and/or deficiencies were noted:

1. The WWTP was running and appeared to be receiving adequate air. There was no objectionable odor.
2. The clarifier contained lots of solids; it appears it's time to scrape down and clean out the clarifiers.
3. One surface sand filter cell was flooded with partially treated wastewater which contained a lot of pinfloc. The cell was draining very slowly. The other cell needs vegetation and solids cleaned from it. Both cells may need additional sand to maintain the required 12" of approved sand.

It's understood that you have obtained the services of Mr. Kenneth Lott, who holds a Class IV Wastewater license. But, according to our database, you still have not submitted Discharge Monitoring Reports (DMR) as is required by your National Pollutant Discharge Elimination System (NPDES) permit. Monitoring data required by this permit shall be submitted on Ohio EPA 4500 DMR forms using the electronic Discharge Monitoring Reports (e-DMR) internet application. The e-DMR allows permitted facilities to enter, sign, and submit DMRs on the internet. It is accessed from the Ohio EPA eBusiness Center. The eBusiness Center is found on the following web page:

<http://www.epa.state.oh.us/dsw/edmr/eDMR.aspx>

**SENDER: COMPLETE THIS SECTION**

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Mr. Dalton Smith  
2248 N. Cleveland-Massillon Road P.O. Box  
209  
Bath, OH 44210

2. Article Number

(Transfer from service label)

700832300035495897 *ISW*

PS Form 3811, February 2004

Domestic Return Receipt

**COMPLETE THIS SECTION ON DELIVERY**

A. Signature

X

*Dalton Smith*

- Agent
- Addressee

B. Received by (Printed Name)

*DALTON SMITH*

C. Date of Delivery

*2/3/12*

D. Is delivery address different from item 1?  Yes  
If YES, enter delivery address below:  No

3. Service Type

- Certified Mail
- Registered
- Insured Mail
- Express Mail
- Return Receipt for Merchandise
- C.O.D.

4. Restricted Delivery? (Extra Fee)

Yes

102595-02-M-1540