



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: **Notice of Violation**
Wood County
Village Green MHP WWTP
Ohio EPA Permit No. 2PY00008
NPDES Permit No. OH0095117

February 15, 2012

Mr. David Nightingale
Village Green MHP
7630 Reitz Road
Perrysburg, Ohio 43551

Dear Mr. Nightingale:

A review of the self-monitoring reports for the Village Green Mobile Home Park (MHP) wastewater treatment plant (WWTP) covering the months of December 2008 through December 2011 indicates violations of the conditions of your National Pollutant Discharge Elimination System (NPDES) permit. The specific instances of noncompliance are enclosed.

Please check your flow monitoring. You have been reporting 300,000 gallons per day, every day, while the size of your WWTP is rated at 45,000 gallons per day. Please also be aware that your flow monitoring is required to be an actual rate, not an estimated one.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in Part III - General Conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

The Ohio EPA strongly encourages pollution prevention as the preferred approach for waste management. The first priority of pollution prevention is to eliminate the generation of wastes and pollutants at the source (source reduction). For those wastes or pollutants that are generated, the second priority is to recycle or reuse them in an environmentally sound manner. You can benefit economically, help preserve the environment, and improve your public image by implementing pollution prevention programs. Information about Ohio EPA's Office of Compliance Assistance & Pollution Prevention can be found by calling (614) 644-3469 or on the Ohio EPA's website at <http://www.epa.state.oh.us/ocapp/ocapp.html>.

If you have any questions, please feel free to contact this office.

Sincerely,

Patricia A. Tebbe, P.E.
Division of Surface Water

/jlm

Enclosure

pc: Dan Wickard, NWWSD
ec: Inspection Tracking

Country Manor Estates
 December 1, 2008 through December 31, 2011
 NPDES Violations

date	station	viotype	rptcode	parameter	lmttype	limit	rptvalue
July, 2009							
07/01/09	001	Limit	00530	Suspended Solids	30D Qty	2.0	4.6
07/01/09	001	Limit	00610	Ammonia	30D Qty	0.26	0.78
07/01/09	001	Limit	80082	CBOD 5 day	30D Qty	1.8	4.4
07/07/09	001	Limit	00530	Suspended Solids	1D Qty	3.1	7.9
07/07/09	001	Limit	00610	Ammonia	1D Qty	0.39	0.86
07/07/09	001	Limit	80082	CBOD 5 day	1D Qty	2.6	3.4
07/21/09	001	Limit	00530	Suspended Solids	1D Qty	3.1	3.4
07/21/09	001	Limit	80082	CBOD 5 day	1D Qty	2.6	9.1
07/21/09	001	Limit	00610	Ammonia	1D Qty	0.39	1
07/28/09	001	Limit	00530	Suspended Solids	1D Qty	3.1	6.8
07/28/09	001	Limit	80082	CBOD 5 day	1D Qty	2.6	4.5
07/28/09	001	Limit	00610	Ammonia	1D Qty	0.39	1.1
May, 2011							
05/01/11	001	Limit	00610	Ammonia	30D Qty	0.26	0.27