



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 22, 2012

Re: Pike County
Piketon WTP
Notice of Violation
01Y00103*AD; OH0134830
Correspondence (IWW)

Mayor Bill Spencer
Village of Piketon
109 Third Street
Piketon, Ohio 45661

Dear Mr. Spencer:

We have reviewed your self-monitoring reports covering the months of July through December 2011 for the Piketon Water Treatment Plant. Our review indicates violations of the conditions in your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	01044	Iron, Suspended (Fe)	30D Conc	1000	2588.	7/1/2011
001	01044	Iron, Suspended (Fe)	30D Qty	0.147	.25469	7/1/2011
001	01044	Iron, Suspended (Fe)	1D Conc	2000	3300.	7/21/2011
001	01044	Iron, Suspended (Fe)	1D Qty	0.293	.32475	7/21/2011
001	01044	Iron, Suspended (Fe)	1D Conc	2000	3300.	7/28/2011
001	01044	Iron, Suspended (Fe)	1D Qty	0.293	.32475	7/28/2011
001	01044	Iron, Suspended (Fe)	30D Conc	1000	1380.	8/1/2011
001	01044	Iron, Suspended (Fe)	1D Conc	2000	3300.	8/18/2011
001	50060	Chlorine, Total Residual	1D Conc	0.038	.15	12/9/2011

*7 D Conc is equal to average weekly concentration limit.
30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences.

If there are any questions, please contact me at (740) 380-5268.

Sincerely,



Jack Knapp
District Representative
Division of Surface Water

JK/dh

c: Rhonda Clemmons, Village of Piketon