



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

February 17, 2012

**Re:** Meigs County  
Pomeroy WWTP  
Self-Monitoring Report Violations  
Ohio EPA Permit 0PB00032  
NPDES Permit OH0021725  
Correspondence (PWW)

Mayor and Council  
Village of Pomeroy  
320 East Main Street  
Pomeroy, Ohio 45769

Dear Mayor and Council:

We have received your self-monitoring report covering the month of July through December 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	31616	Fecal Coliform	7D Conc	400	3795.52	8/22/2011
001	31616	Fecal Coliform	7D Conc	400	470.	10/8/2011

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

We have reviewed your report addressing the reasons for the above violations and the actions being taken to prevent further occurrences. Hopefully, these actions will prevent any recurrence so that enforcement action will not be required. No additional information is requested at this time.

If there are any questions, please contact me at (740) 380-5266.

Sincerely,

Cynthia Yandrich  
District Representative  
Division of Surface Water

CY/dh