



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

February 23, 2012

**Re:** Tuscarawas County  
Village of Strasburg WWTP  
Notice of Violation  
OPB00043, OH0027553  
Correspondence (PWW)

Mayor and Council  
Village of Strasburg  
358 5th Street  
Strasburg, Ohio 44680

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of October 2010 through December 2011 for the Strasburg WWTP. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

**Numeric Violations:**

| Station | Reporting Code | Parameter              | Violation Date | Limit Type* | Limit | Reported Value |
|---------|----------------|------------------------|----------------|-------------|-------|----------------|
| 001     | 00530          | Total Suspended Solids | 8/22/2011      | 7D Conc     | 36    | 40.5           |

\* 7D Conc is equal to the weekly average concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,



Tim Fulks  
District Representative  
Division of Surface Water

TF/dh

c: Mr. Ronald Lambert, Superintendent, Strasburg WWTP