



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 23, 2012

Re: Tuscarawas County
Mineral City WWTP
Notice of Violation
OPB00053, OH0021504
Correspondence (PWW)

Mr. Charles Regula, Sanitary Engineer
Tuscarawas County Metropolitan Sewer District
9944 Wilkshire Blvd., NE
Bolivar, Ohio 44612

Dear Mr. Regula:

We have received your self-monitoring reports covering the months of December 2010 through December 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Limit Type*	Limit	Reported Value	Violation Date
001	00400	pH	1D Conc	9.0	11.	1/16/2011
001	00400	pH	1D Conc	9.0	10.6	1/17/2011
April 2011						
001	00530	Total Suspended Solids	30D Conc	30	53.	4/1/2011
001	00530	Total Suspended Solids	30D Qty	17	39.6426	4/1/2011
001	00530	Total Suspended Solids	7D Conc	45	163.5	4/15/2011
001	00530	Total Suspended Solids	7D Qty	26	127.681	4/15/2011
May 2011						
001	00530	Total Suspended Solids	30D Conc	30	83.625	5/1/2011
001	00530	Total Suspended Solids	7D Conc	45	325.	5/1/2011
001	00530	Total Suspended Solids	30D Qty	17	69.3322	5/1/2011
001	00530	Total Suspended Solids	7D Qty	26	271.914	5/1/2011
June 2011						
001	00530	Total Suspended Solids	30D Conc	30	86.875	6/1/2011
001	00530	Total Suspended Solids	30D Qty	17	34.9738	6/1/2011
001	00530	Total Suspended Solids	7D Conc	45	331.5	6/8/2011
001	00530	Total Suspended Solids	7D Qty	26	133.752	6/8/2011

* 1D Conc is equal to the daily maximum concentration limit.
7D Conc is equal to the weekly average concentration limit.
7D Qty is equal to the weekly average loading limit.
30D Conc is equal to the monthly average concentration limit.
30D Qty is equal to the monthly average loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,



Tim Fulks
District Representative
Division of Surface Water

TF/dh

c: Mr. Ed Wilson, Tuscarawas County Water and Sewer District