



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

February 23, 2012

**Re:** Tuscarawas County  
City of New Philadelphia WWTP  
Notice of Violations  
OPD00012, OH0026689  
Correspondence (PWW)

Mayor and Council  
City of New Philadelphia  
150 East High Avenue  
New Philadelphia, Ohio 44663

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of January through December 2011 for the New Philadelphia WWTP. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

**Numeric Violations:**

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	31648	E. coli	10/1/2011	30D Conc	126	160.461
001	61942	pH, Minimum	11/28/2011	1D Conc	6.5	6.4

\* 1D Conc is equal to the daily maximum concentration limit.  
30D Conc is equal to the monthly average concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,



Tim Fulks  
District Representative  
Division of Surface Water

TF/dh

c: Aaron Hixenbaugh, Superintendent, New Philadelphia WWTP