



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 23, 2012

Re: Jefferson County
City of Steubenville WWTP
Notice of Violation
Significant Non-compliance
NPDES Permit OPD00014*JD
Correspondence (PWW)

Mayor and Council
City of Steubenville
300 Market Street
Steubenville, Ohio 43952

Dear Mayor and Council:

NOTICE OF VIOLATION – Significant Non-Compliance

We have received self-monitoring reports covering January through December 2011 for the referenced facility. Our review indicated the following violations of the conditions of your NPDES permit.

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
002	31616	Fecal Coliform	30D Conc	200	450000.	8/1/2011
001	50060	Chlorine, Total Residual	1D Conc	0.038	.14	8/11/2011
002	31616	Fecal Coliform	7D Conc	400	450000.	8/22/2011
002	31616	Fecal Coliform	30D Conc	200	1166.7	9/1/2011
002	31616	Fecal Coliform	7D Conc	400	1166.7	9/22/2011

Non-compliance notification was provided for the violations shown. The data for 8/11/2011 was reportedly entered wrong and should be corrected to 0.014. A hypochlorite feed line had reportedly become restricted leading to fecal violations at 002. Corrective actions were taken to ensure future compliance.

If you have any questions, please feel free to contact me at (740) 380-5272.

Sincerely,

Aaron Pennington
District Representative
Division of Surface Water

AP/dh

c: Chuck Murphy, City of Steubenville WWTP