



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

February 22, 2012

**Re:** Hocking County  
Rockbridge WWTP  
Notice of Violation  
OPH00014\*CD; OH0120430  
Correspondence (PWW)

Hocking County Commissioners  
1 E. Main Street  
Logan, Ohio 43138

Dear Board of Commissioners:

We have reviewed your self-monitoring reports covering the months of July through December of 2011 for the Rockbridge Wastewater Treatment Plant. Our review indicates violations of the conditions in your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
001	00530	Total Suspended Solids	30D Qty	3.18	3.35446	11/1/2011
001	80082	CBOD 5 day	7D Qty	4.24	4.98106	11/22/2011
001	00530	Total Suspended Solids	7D Qty	4.77	9.60633	11/22/2011
001	00530	Total Suspended Solids	30D Qty	3.18	4.11997	12/1/2011
001	00530	Total Suspended Solids	7D Qty	4.77	10.9689	12/1/2011
001	80082	CBOD 5 day	30D Qty	2.64	3.58061	12/1/2011
001	80082	CBOD 5 day	7D Qty	4.24	9.5382	12/1/2011

\* 7 D Conc is equal to average weekly concentration limit.

\* 30 D Conc is equal to average monthly concentration limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a response has been sent prior to this letter, no further action is required.

If there are any questions, please contact me at (740) 380-5268.

Sincerely,



Jack Knapp  
District Representative  
Division of Surface Water

JK/dh

c: Kevin Loudin, Operator