



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 23, 2012

Re: Tuscarawas County
Sandyville-East Sparta WWTP
Notice of Violation
OPJ00007, OH0048615
Correspondence (PWW)

Mr. Charles Regula, Sanitary Engineer
Tuscarawas County Metropolitan Sewer District
9944 Wilkshire Blvd., NE
Bolivar, Ohio 44612

Dear Mr. Regula:

We have received your self-monitoring reports covering the months of December 2010 through December 2011 for the Sandyville-East Sparta WWTP. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Limit Type*	Limit	Reported Value	Violation Date
581	01003	Arsenic, Total In Slud	1D Conc	75	189.	12/6/2010
January 2011						
001	00400	pH	1D Conc	6.5	5.5	1/16/2011
001	00400	pH	1D Conc	9.0	9.8	1/17/2011

* 1D Conc is equal to the daily maximum concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

A handwritten signature in blue ink, appearing to read "Tim Fulks".

Tim Fulks
District Representative
Division of Surface Water

TF/dh

c: Mr. Ed Wilson, Tuscarawas County Water and Sewer District