



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 24, 2012

Re: Tuscarawas County
Tolloti Plastic Pipe, Inc.
Notice of Violation
0IQ00025, OH0099767
Correspondence (IWW)

Mr. Ted Tolloti
Tolloti Plastic Pipe, Inc.
P.O. Box 508
New Philadelphia, Ohio 44663-0508

Dear Mr. Tolloti:

We have received your self-monitoring reports covering the months of July through December 2011, for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	00310	Biochemical Oxygen Dem	7/27/2011	1D Conc	26	41.
001	00530	Total Suspended Solids	7/27/2011	1D Conc	19	37.

* 1D Conc is equal to the daily maximum concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

Tim Fulks
District Representative
Division of Surface Water

TF/dh