



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 24, 2012

Re: Tuscarawas County
Sugar creek WWTP
Notice of Violation
OPB00070, OH0027618
Correspondence (PWW)

Mayor and Council
Village of Sugar creek
410 South Broadway
Sugar creek, Ohio 44681

Dear Mayor and Council:

We have received your self-monitoring reports covering the months of August 2010 through December 2011 for the Sugar creek WWTP. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Limit Type*	Limit	Reported Value	Violation Date
001	00665	Phosphorus, Total (P)	1D Qty	1.9	2.44178	5/3/2011

* 1D Qty is equal to the daily maximum loading limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

Tim Fulks
District Representative
Division of Surface Water

TF/dh

c: Mr. Jim Cappon, Superintendent of Wastewater, Village of Sugar creek