Ohio Environmental Protection Agency
John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

February 24, 2012

Re: Tuscarawas County
Kerr Allotment WWTP
Notice of Violation
0PG00031, OH0048437
Correspondence (PWW)

Mr. Charles Regula, Sanitary Engineer
Tuscarawas County Metropolitan Sewer District
9944 Wilkshire Blvd., NE
Bolivar, Ohio 44612

Dear Mr. Regula:

We have received your self-monitoring reports covering the months of January through December 2011 for the referenced facility. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Numeric Violations:

Station	Reporting Code	Parameter	Violation Date	Limit Type*	Limit	Reported Value
001	00530	Total Suspended Solids	2/1/2011	30D Conc	30	50.
001	00530	Total Suspended Solids	2/1/2011	7D Conc	45	50.

* 7D Conc is equal to the weekly average concentration limit.
30D Conc is equal to the monthly average concentration limit.

Please submit within **10** days upon receipt of this letter as to the reasons for the above permit violations and actions being taken to prevent further occurrences. If a prior explanation of these violations has been sent no further action is required.

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements specified in your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

Southeast District Office
2195 Front Street
Logan, OH 43138-8637

740 | 385 8501
740 | 385 6490 (fax)
www.epa.ohio.gov

If there are any questions, please contact me at (740) 380-5418.

Sincerely,

Tim Fulks
District Representative
Division of Surface Water

TF/dh

c: Mr. Ed Wilson, Tuscarawas County Water and Sewer District