



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 24, 2012

Re: Adams County
Peebles WWTP
Self-Monitoring Report Violations
NPDES Permit 0PB00069*GD
Correspondence (PWW)

Mr. Jim Gulley
Peebles WWTP
195 Chautauqua Street
Peebles, Ohio 45660

Dear Mr. Gulley:

We have received your self-monitoring report covering the months of July through November 2011 for your wastewater treatment plant. Our review indicates violations of the conditions of your NPDES permit. The specific instances of noncompliance and/or deficiencies are as follows:

Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
November 2011	001	CBOD 5 day	7D Qty	23.9	25.0686	11/22/2011

Note: 1D Qty is equal to a maximum daily loading limit.
1D Conc is equal to the maximum daily concentration limit.
30 D Conc is equal to average monthly concentration limit.
30 D Qty is equal to the average monthly loading limit.

Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code Chapter 6111.

Within 14 days from receipt of this letter submit a letter to this office outlining the reasons for the above permit violations and actions being taken to prevent further occurrences. No action is required if you have already submitted documentation outlining the causes of these violations and corresponding corrective actions.

If there are any questions, please contact me at (740) 380-5277.

Sincerely,

Aaron Wolfe
Storm Water Coordinator
Division of Surface Water

AW/dh