



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

Re: Wood County
Perrysburg Township
Five Points MHP
NPDES

February 21, 2012

Ms. Michelle Meyers
Five Points MHP
24370 State Route 199 Lot 1
Perrysburg, Ohio 43551

Dear Ms. Meyers:

On October 20, 2011, an inspection was made of the wastewater treatment plant (WWTP) serving the Five Points Mobile Home Park (MHP) located at the intersection of Five Point Road and State Route 199 in Perrysburg Township, Wood County. At the time of the inspection, all components of the system were in operation. The following are observations made on the operation of the wastewater facilities:

- Trash traps were pumped the previous week by NAT.
- Aeration tanks had good aeration with both the return sludge and skimmer in; the return sludge was light in color.
- Final effluent was turbid.
- Sand filters clean, using the east side. There was ponding in the east sand filter.
- Chlorination and dechlorination tablets were in the tube feeders with foam present in chlorine contact tank.
- Operator logs were not available for review. Operator logs are to be kept on site and available at all times.

This wastewater treatment plant has been out of compliance with its National Pollutant Discharge Elimination System (NPDES) permit. The specific instances of noncompliance are enclosed.


Ms. Michelle Meyers
February 21, 2012
Page Two

Please be advised that failure to comply with the effluent limitations and/or monitoring requirements, including adequate laboratory controls, appropriate quality assurance procedures, and records retention, as specified in Part III - General Conditions of your NPDES permit may be cause for enforcement action pursuant to Ohio Revised Code, Chapter 6111. If these violations continue to occur and if satisfactory progress is not made, it may be necessary to initiate enforcement action to achieve compliance.

Please inform this office in writing, within 10 days of receipt of this letter, as to the description of the actions taken or proposed to prevent further violations of this nature. Your response should include the dates, either actual or proposed, for completion of the actions.

If you have any questions, please contact me by e-mail at patricia.tebbe@epa.state.oh.us or by phone at (419) 373-3016.

Sincerely,



Patricia A. Tebbe P.E.
Division of Surface Water

/jlm

Enclosure

cc: Inspection Tracking

**Five Point MHP
November 1, 2009 through January 31, 2012
NPDES Violations**

date	station	viotype	rptcode	parameter	lmttype	limit	rptvalue
February 2010							
02/01/10	001	Limit	00610	Ammonia	30D Conc	3.0	7.2
02/01/10	001	Freq	00056	Flow Rate	1/Day	28 days	none
02/23/10	001	Limit	00610	Ammonia	1D Conc	4.5	7.2
March 2010							
03/01/10	001	Freq	00056	Flow Rate	1/Day	31 days	none
May 2010							
05/01/10	001	Freq	50060	Chlorine	1/2Weeks	1	none
05/01/10	001	Freq	00056	Flow Rate	1/Day	31 days	none
June 2010							
06/01/10	001	Freq	00056	Flow Rate	1/Day	30 days	none
06/29/10	001	Limit	50060	Chlorine	1D Conc	0.019	.07
06/29/10	001	Limit	00300	Dissolved Oxygen	1D Conc	6.0	5.3
July 2010							
07/01/10	001	Freq	00056	Flow Rate	1/Day	31 days	none
07/13/10	001	Limit	50060	Chlorine	1D Conc	0.019	34.6
August 2010							
08/10/10	001	Limit	50060	Chlorine	1D Conc	0.019	.07
September 2010							
09/14/10	001	Limit	50060	Chlorine	1D Conc	0.019	.08
May 2011							
05/15/11	001	Freq	50060	Chlorine	1/2Weeks	1	none
05/31/11	001	Limit	50060	Chlorine	1D Conc	0.019	.22
June 2011							
06/14/11	001	Limit	00300	Dissolved Oxygen	1D Conc	6.0	5.2
06/21/11	001	Limit	50060	Chlorine	1D Conc	0.019	.06
July 2011							
07/06/11	001	Limit	00300	Dissolved Oxygen	1D Conc	6.0	5.
August 2011							
08/01/11	001	Limit	31616	Fecal Coliform	30D Conc	1000	10000.
08/03/11	001	Limit	31616	Fecal Coliform	1D Conc	2000	10000.
08/16/11	001	Limit	00300	Dissolved Oxygen	1D Conc	6.0	5.5
December 2011							
12/12/11	001	Limit	00300	Dissolved Oxygen	1D Conc	6.0	4.25
12/19/11	001	Limit	00300	Dissolved Oxygen	1D Conc	6.0	3.73

Five Point MHP
November 1, 2009 through January 31, 2012
NPDES Violations

date	station	viotype	rptcode	parameter	lmttype	limit	rptvalue
January 2012							
01/04/12	001	Limit	00300	Dissolved Oxygen	1D Conc	6.0	3.81
01/09/12	001	Limit	00300	Dissolved Oxygen	1D Conc	6.0	3.2
01/17/12	001	Limit	00300	Dissolved Oxygen	1D Conc	6.0	4.04
01/24/12	001	Limit	00300	Dissolved Oxygen	1D Conc	6.0	4.2